

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity	353.9 cd per klm.
(Luminaire orientation as tested.)	0.0 degrees vertical
	0.0 degrees horizontal

Beam Spread	At 10% of Imax	166.5V x 167.7H
	At 50% of Imax	109.6V x 113.0H
	At 90% of Imax	28.0V x 41.9H

Beam Flux	Total	1000.0 lumens per klm.
	To 10% of Imax	986.4 lumens per klm.
	To 50% of Imax	687.6 lumens per klm.
	To 90% of Imax	91.6 lumens per klm.

Upward LOR	0.4 %
Downward LOR	99.6 %


Luminaire Efficiency(Light Output Ratio)	100.0 %
--	---------

H(β) Range:-90 - 90DEG
H(β) Interval: 0.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:ADMIN
Test Date:2023-02-04

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.352
Humidity:65.0%
Test Distance:13.563m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

Test:U:12.03V I:0.7924A P:6.516W PF:0.6836 Freq:59.99Hz Lamp Flux:183.175x1 lm		
NAME: LED LANDSCAPE LIGHT	TYPE:Copper Pathlight 6.5W 12V E27	MODEL: A9B1-6.5W-A
SPEC.:	DIM.:	SERIAL No.:1
MFR.: EVERFINE	SUR.:	Shielding Angle:



DATA OF LAMP		Eff:28.11lm/W	
MODEL	A9B1-6.5W-A	Imax (cd)	64.83
NOMINAL POWER(W)	6.5	AVAILABILITY(%)	98.6
RATED VOLTAGE (V)	12	Avai. FLUX(lm)	180.6
NOMINAL FLUX(lm)	183.175	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	183.2
TEST VOLTAGE (V)	12	θ @50% (H,V)	113,110DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM																UNIT:lm		Φ t	Φ a
	0.00	0.01	0.03	0.04	0.06	0.08	0.10	0.11	0.12	0.12	0.11	0.10	0.08	0.06	0.04	0.03	0.01	0.00	1.12	0.53
90	0.01	0.03	0.08	0.15	0.22	0.29	0.35	0.40	0.42	0.43	0.40	0.36	0.29	0.22	0.15	0.08	0.03	0.01	3.92	3.75
80	0.01	0.05	0.13	0.23	0.35	0.47	0.58	0.66	0.70	0.70	0.66	0.58	0.48	0.36	0.24	0.13	0.05	0.01	6.37	6.32
70	0.01	0.07	0.17	0.32	0.48	0.65	0.80	0.91	0.96	0.96	0.91	0.80	0.66	0.49	0.32	0.18	0.07	0.01	8.78	8.75
60	0.01	0.08	0.21	0.40	0.61	0.82	1.01	1.14	1.21	1.21	1.14	1.01	0.82	0.61	0.40	0.22	0.08	0.01	11.0	11.0
50	0.02	0.09	0.25	0.47	0.72	0.97	1.19	1.35	1.42	1.42	1.34	1.18	0.97	0.72	0.47	0.25	0.10	0.02	12.9	12.9
40	0.02	0.10	0.28	0.52	0.80	1.09	1.34	1.52	1.60	1.60	1.51	1.33	1.08	0.80	0.52	0.28	0.11	0.02	14.5	14.5
30	0.02	0.11	0.30	0.56	0.87	1.18	1.45	1.65	1.74	1.73	1.64	1.44	1.17	0.86	0.56	0.30	0.11	0.02	15.7	15.7
20	0.02	0.11	0.31	0.58	0.90	1.23	1.53	1.75	1.85	1.84	1.73	1.50	1.21	0.89	0.58	0.31	0.12	0.02	16.5	16.5
10	0.02	0.11	0.31	0.58	0.90	1.23	1.53	1.76	1.88	1.87	1.74	1.51	1.22	0.90	0.58	0.31	0.12	0.02	16.6	16.6
0	0.02	0.11	0.30	0.56	0.87	1.18	1.47	1.68	1.78	1.78	1.66	1.45	1.17	0.86	0.56	0.30	0.11	0.02	15.9	15.9
-10	0.02	0.10	0.28	0.52	0.81	1.10	1.36	1.55	1.64	1.64	1.54	1.35	1.09	0.80	0.52	0.28	0.11	0.02	14.7	14.7
-20	0.02	0.09	0.25	0.47	0.72	0.98	1.21	1.37	1.46	1.46	1.37	1.20	0.97	0.72	0.47	0.25	0.10	0.02	13.1	13.1
-30	0.01	0.08	0.21	0.40	0.61	0.83	1.02	1.17	1.24	1.24	1.16	1.02	0.83	0.61	0.40	0.22	0.08	0.01	11.2	11.1
-40	0.01	0.07	0.17	0.32	0.49	0.66	0.81	0.92	0.98	0.98	0.92	0.81	0.66	0.49	0.32	0.17	0.07	0.01	8.87	8.84
-50	0.01	0.05	0.13	0.23	0.35	0.47	0.58	0.66	0.70	0.70	0.66	0.58	0.48	0.36	0.24	0.13	0.05	0.01	6.38	6.32
-60	0.01	0.03	0.08	0.14	0.21	0.29	0.35	0.39	0.42	0.42	0.40	0.35	0.29	0.22	0.15	0.08	0.03	0.01	3.85	3.67
-70	0.00	0.01	0.03	0.04	0.06	0.08	0.09	0.10	0.10	0.10	0.10	0.09	0.08	0.06	0.04	0.03	0.01	0.00	1.03	0.46
-80	0.00	0.01	0.03	0.04	0.06	0.08	0.09	0.10	0.10	0.10	0.10	0.09	0.08	0.06	0.04	0.03	0.01	0.00	1.03	0.46
-90	0.00	0.01	0.03	0.04	0.06	0.08	0.09	0.10	0.10	0.10	0.10	0.09	0.08	0.06	0.04	0.03	0.01	0.00	1.03	0.46
HORIZONTAL (DEG)																				
Φ t	0.22	1.34	3.50	6.53	10.0	13.6	16.8	19.1	20.2	20.2	19.0	16.7	13.5	10.0	6.56	3.55	1.37	0.22	182	---
Φ a	0.09	1.19	3.37	6.41	9.94	13.5	16.7	19.0	20.2	20.1	18.9	16.6	13.5	9.93	6.44	3.43	1.24	0.10	---	181

one-half-peak spread: U:47.5,D:53.9 , L:52.9,R:43.8


NEMA Beam Type: Type 7

H(β) Range:-90 - 90DEG
H(β) Interval: 0.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:ADMIN
Test Date:2023-02-04

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.352
Humidity:65.0%
Test Distance:13.563m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

Test:U:12.03V I:0.7924A P:6.516W PF:0.6836 Freq:59.99Hz Lamp Flux:183.175x1 lm		
NAME: LED LANDSCAPE LIGHT	TYPE:Copper Pathlight 6.5W 12V 12300K	
SPEC.:	DIM.:	SERIAL No.:1
MFR.: EVERFINE	SUR.:	Shielding Angle:




H(β) Range:-90 - 90DEG
H(β) Interval: 0.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:ADMIN
Test Date:2023-02-04

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.352
Humidity:65.0%
Test Distance:13.563m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


Test:U:12.03V I:0.7924A P:6.516W PF:0.6836 Freq:59.99Hz Lamp Flux:183.175x1 lm		
NAME: LED LANDSCAPE LIGHT	TYPE:Copper Pathlight 6.5W 12V E230K	
SPEC.:	DIM.:	SERIAL No.:1
MFR.: EVERFINE	SUR.:	Shielding Angle:



H(β) Range:-90 - 90DEG
H(β) Interval: 0.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:ADMIN
Test Date:2023-02-04

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.352
Humidity:65.0%
Test Distance:13.563m [K=1.0000]
Remarks:

Planar Illuminance Curve




H(β) Range:-90 - 90DEG
H(β) Interval: 0.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:ADMIN
Test Date:2023-02-04

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.352
Humidity:65.0%
Test Distance:13.563m [K=1.0000]
Remarks:

AAI Figure

Test:U:12.03V I:0.7924A P:6.516W PF:0.6836 Freq:59.99Hz Lamp Flux:183.175x1 lm		
NAME: LED LANDSCAPE LIGHT	TYPE:Copper Pathlight 6.5W 12V 12300K	
SPEC.:	DIM.:	SERIAL No.:1
MFR.: EVERFINE	SUR.:	Shielding Angle:



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H(β) Range:-90 - 90DEG
H(β) Interval: 0.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:ADMIN
Test Date:2023-02-04

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.352
Humidity:65.0%
Test Distance:13.563m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:12.03V I:0.7924A P:6.516W PF:0.6836 Freq:59.99Hz Lamp Flux:183.175x1 lm		
NAME: LED LANDSCAPE LIGHT	TYPE:Copper Pathlight 6.5W 12V E27 BUCK	2400K
SPEC.:	DIM.:	SERIAL No.:1
MFR.: EVERFINE	SUR.:	Shielding Angle:

Table--1

UNIT: cd

H (DEG) V (DEG)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-180	0.00	0.00	0.00	0.00	0.00	0.00	0.04	0.09	0.13	0.19	0.22	0.27	0.32	0.33	0.36	0.40	0.42	0.45	0.47
-170	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.08	0.14	0.18	0.22	0.25	0.30	0.33	0.36	0.40	0.42	0.44	0.45
-160	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.07	0.12	0.15	0.20	0.24	0.27	0.31	0.34	0.36	0.38	0.39	0.40
-150	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.05	0.08	0.13	0.16	0.21	0.23	0.26	0.28	0.31	0.33	0.34	0.34
-140	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.02	0.05	0.08	0.12	0.15	0.16	0.19	0.22	0.23	0.24	0.25	0.26
-130	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.02	0.03	0.06	0.09	0.10	0.13	0.14	0.16	0.16	0.17	0.17
-120	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.02	0.03	0.04	0.05	0.06	0.08	0.09	0.10	0.11
-110	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.01
-100	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-80	0.00	1.37	2.58	3.10	3.33	3.59	4.04	4.88	5.85	6.86	7.40	7.89	8.29	8.64	8.89	9.09	9.22	9.30	9.32
-70	0.00	2.71	3.81	4.85	6.57	8.05	9.33	10.6	11.9	13.0	14.1	15.1	16.1	16.8	17.4	17.9	18.2	18.4	18.5
-60	0.00	3.49	5.00	7.30	9.35	11.4	13.5	15.6	17.6	19.4	21.2	22.7	24.1	25.3	26.4	27.1	27.6	27.9	28.0
-50	0.00	3.94	6.37	9.15	11.9	14.7	17.6	20.4	23.1	25.6	27.9	30.1	31.8	33.5	34.8	35.7	36.4	36.7	36.7
-40	0.00	4.38	7.50	10.8	14.2	17.8	21.3	24.7	28.0	31.2	34.0	36.5	38.8	40.8	42.0	43.7	44.4	44.6	44.6
-30	0.00	4.78	8.39	12.2	16.2	20.3	24.4	28.4	32.2	35.7	39.0	41.9	44.6	46.6	48.6	50.1	51.0	51.7	51.7
-20	0.00	5.10	9.02	13.2	17.7	22.2	26.8	31.2	35.3	39.2	42.7	45.9	49.0	51.5	53.8	55.2	56.2	56.7	56.8
-10	0.00	5.31	9.39	13.8	18.6	23.5	28.2	32.8	37.2	41.5	45.3	48.7	51.9	54.7	57.0	58.9	60.1	60.7	60.6
0	0.00	5.41	9.51	14.1	19.0	24.0	28.8	33.4	38.0	42.3	46.1	49.9	53.1	56.3	58.5	60.6	61.9	63.6	64.1
10	0.00	5.32	9.39	13.8	18.6	23.5	28.2	32.8	37.1	41.4	45.1	48.5	51.6	54.3	56.6	58.2	59.1	59.4	58.8
20	0.00	5.12	9.04	13.2	17.7	22.2	26.8	31.1	35.2	38.9	42.5	45.6	48.5	50.9	52.9	54.3	55.1	55.5	55.2
30	0.00	4.79	8.41	12.2	16.2	20.3	24.4	28.4	32.0	35.6	38.6	41.5	44.0	46.1	47.8	48.9	49.9	50.1	49.9
40	0.00	4.39	7.54	10.8	14.2	17.8	21.3	24.6	27.9	30.9	33.7	36.1	38.3	40.3	41.5	42.6	43.3	43.6	43.6
50	0.00	3.95	6.47	9.21	12.0	14.8	17.6	20.4	23.0	25.5	27.8	29.8	31.4	33.0	34.4	35.3	35.8	36.0	36.0
60	0.00	3.49	5.10	7.39	9.44	11.5	13.6	15.6	17.6	19.4	21.1	22.7	24.0	25.1	26.1	26.8	27.3	27.6	27.7
70	0.00	2.71	3.82	5.02	6.76	8.17	9.47	10.8	12.0	13.1	14.2	15.3	16.1	16.9	17.5	18.0	18.3	18.5	18.6
80	0.00	1.37	2.58	3.10	3.35	3.71	4.38	5.41	6.37	7.20	7.70	8.16	8.57	8.92	9.21	9.44	9.61	9.72	9.77
90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
100	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
110	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
120	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
130	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.03	0.03	0.06	0.06	0.07	0.09	0.11	0.11
140	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.04	0.07	0.10	0.14	0.16	0.17	0.16	0.16	0.16	0.15
150	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.05	0.10	0.14	0.17	0.18	0.21	0.22	0.25	0.28	0.28	0.28
160	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.05	0.10	0.14	0.18	0.20	0.24	0.29	0.30	0.30	0.32	0.33	0.33
170	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.07	0.13	0.17	0.20	0.24	0.29	0.31	0.34	0.37	0.39	0.42	0.43
180	0.00	0.00	0.00	0.00	0.00	0.00	0.04	0.09	0.13	0.19	0.22	0.27	0.32	0.33	0.36	0.40	0.42	0.45	0.46

H(β) Range:-90 - 90DEG
H(β) Interval: 0.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:ADMIN
Test Date:2023-02-04

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.352
Humidity:65.0%
Test Distance:13.563m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:12.03V I:0.7924A P:6.516W PF:0.6836 Freq:59.99Hz Lamp Flux:183.175x1 lm		
NAME: LED LANDSCAPE LIGHT	TYPE:Copper Pathlight 6.5W 12V 12300K	
SPEC.:	DIM.:	SERIAL No.:1
MFR.: EVERFINE	SUR.:	Shielding Angle:

Table--2

UNIT: cd

H (DEG) V (DEG)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	
-180	0.46	0.45	0.42	0.36	0.33	0.29	0.29	0.27	0.18	0.15	0.11	0.08	0.02	0.01	0.00	0.00	0.00	0.01	
-170	0.44	0.43	0.40	0.36	0.33	0.30	0.29	0.26	0.18	0.14	0.12	0.07	0.02	0.01	0.00	0.00	0.00	0.01	
-160	0.39	0.38	0.36	0.33	0.31	0.29	0.27	0.20	0.17	0.13	0.12	0.05	0.01	0.01	0.00	0.00	0.00	0.01	
-150	0.34	0.32	0.31	0.30	0.28	0.25	0.20	0.18	0.15	0.12	0.08	0.03	0.01	0.00	0.00	0.00	0.00	0.01	
-140	0.26	0.25	0.24	0.22	0.19	0.18	0.15	0.14	0.12	0.08	0.03	0.02	0.01	0.00	0.00	0.00	0.00	0.01	
-130	0.17	0.16	0.16	0.15	0.14	0.13	0.12	0.08	0.05	0.03	0.02	0.01	0.00	0.00	0.00	0.00	0.00	0.01	
-120	0.10	0.10	0.09	0.07	0.06	0.05	0.03	0.02	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	
-110	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	
-100	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	
-80	9.32	9.26	9.14	8.96	8.72	8.40	8.03	7.56	7.02	6.01	5.05	4.22	3.77	3.47	3.15	2.37	0.75	0.01	
-70	18.5	18.3	18.0	17.5	16.9	16.2	15.3	14.3	13.2	12.1	10.8	9.57	8.31	6.80	5.07	3.97	2.48	0.01	
-60	27.9	27.6	27.1	26.4	25.4	24.2	22.8	21.3	19.6	17.8	15.9	13.8	11.7	9.64	7.59	5.24	3.53	0.01	
-50	36.7	36.4	35.7	34.7	33.4	31.8	30.1	28.0	25.7	23.2	20.6	17.9	15.1	12.2	9.45	6.64	4.09	0.01	
-40	44.6	44.3	43.5	41.9	40.7	38.6	36.4	33.8	31.1	28.2	25.0	21.5	18.1	14.6	11.1	7.82	4.60	0.01	
-30	51.6	50.9	49.9	48.3	46.4	44.4	41.5	38.7	35.5	32.1	28.6	24.6	20.6	16.6	12.5	8.70	5.03	0.01	
-20	56.6	55.8	54.7	53.3	51.1	48.5	45.5	42.3	38.9	35.1	31.2	27.0	22.5	18.0	13.6	9.34	5.36	0.01	
-10	60.6	59.7	58.3	56.2	54.1	51.3	48.2	44.9	41.2	37.1	32.8	28.4	23.7	19.0	14.2	9.73	5.58	0.01	
0	62.7	61.5	59.7	57.7	55.2	52.4	49.1	45.5	41.8	37.6	33.3	29.0	24.1	19.3	14.5	9.87	5.68	0.01	
10	59.2	58.7	57.7	55.7	53.7	51.1	48.0	44.8	41.1	37.0	32.7	28.4	23.7	19.0	14.2	9.74	5.59	0.01	
20	55.4	54.8	53.9	52.4	50.5	48.1	45.2	42.1	38.6	35.0	31.1	27.0	22.4	18.0	13.6	9.35	5.38	0.01	
30	50.0	49.7	48.7	47.5	45.8	43.7	41.2	38.4	35.4	32.0	28.5	24.6	20.6	16.6	12.6	8.72	5.05	0.01	
40	43.6	43.2	42.4	41.3	40.2	38.1	36.1	33.5	30.9	28.1	24.9	21.5	18.1	14.6	11.1	7.86	4.61	0.01	
50	36.0	35.7	35.2	34.3	33.0	31.4	29.8	27.9	25.6	23.2	20.6	17.9	15.1	12.3	9.50	6.74	4.10	0.01	
60	27.6	27.4	26.9	26.2	25.2	24.1	22.8	21.2	19.6	17.8	15.9	13.9	11.8	9.72	7.68	5.34	3.53	0.01	
70	18.5	18.4	18.0	17.6	16.9	16.2	15.4	14.4	13.3	12.2	11.0	9.71	8.42	7.00	5.24	3.98	2.48	0.01	
80	9.74	9.65	9.50	9.28	9.00	8.68	8.30	7.86	7.36	6.53	5.57	4.56	3.90	3.50	3.15	2.37	0.75	0.01	
90	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	
100	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	
110	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	
120	0.00	0.01	0.01	0.01	0.01	0.01	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	
130	0.11	0.09	0.08	0.07	0.07	0.05	0.05	0.04	0.02	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.01	
140	0.16	0.17	0.17	0.17	0.16	0.15	0.11	0.09	0.07	0.05	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.01	
150	0.28	0.28	0.25	0.23	0.23	0.21	0.17	0.16	0.11	0.09	0.06	0.02	0.01	0.00	0.00	0.00	0.00	0.01	
160	0.33	0.32	0.30	0.29	0.28	0.25	0.24	0.18	0.16	0.11	0.10	0.04	0.01	0.01	0.00	0.00	0.00	0.01	
170	0.42	0.40	0.37	0.33	0.31	0.28	0.27	0.24	0.18	0.13	0.11	0.06	0.01	0.01	0.00	0.00	0.00	0.01	
180	0.46	0.45	0.42	0.36	0.33	0.29	0.29	0.27	0.18	0.15	0.11	0.08	0.02	0.01	0.00	0.00	0.00	0.01	

H(β) Range:-90 - 90DEG
H(β) Interval: 0.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:ADMIN
Test Date:2023-02-04

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.352
Humidity:65.0%
Test Distance:13.563m [K=1.0000]
Remarks: